

SSA-180635: Denial-of-Service Vulnerabilities in S7-1500 CPU

Publication Date: 2019-01-08
Last Update: 2019-01-08
Current Version: V1.0
CVSS v3.0 Base Score: 7.5

SUMMARY

Older versions of the S7-1500 CPU are affected by two Denial-of-Service vulnerabilities. Siemens has released updates for the currently supported hardware versions.

AFFECTED PRODUCTS AND SOLUTION

Affected Product and Versions	Remediation
SIMATIC S7-1500 CPU: All versions \geq V2.0 and $<$ V2.5	Update to V2.5 or newer https://support.industry.siemens.com/cs/de/en/view/109478459
SIMATIC S7-1500 CPU: All versions \leq V1.8.5	Update to V2.5 or higher or when this is not possible (because of Hardware restrictions) see recommendations from section workarounds and mitigations

WORKAROUNDS AND MITIGATIONS

Siemens has identified the following specific workarounds and mitigations that customers can apply to reduce the risk:

- Protect network access to port 80/tcp and port 443/tcp of affected devices.
- Apply cell protection concept
- Apply defense-in-depth

GENERAL SECURITY RECOMMENDATIONS

As a general security measure, Siemens strongly recommends to protect network access to devices with appropriate mechanisms. In order to operate the devices in a protected IT environment, Siemens recommends to configure the environment according to Siemens' operational guidelines for Industrial Security (Download: <https://www.siemens.com/cert/operational-guidelines-industrial-security>), and to follow the recommendations in the product manuals.

Additional information on Industrial Security by Siemens can be found at: <https://www.siemens.com/industrialsecurity>

PRODUCT DESCRIPTION

Products of the SIMATIC S7-1500 CPU family have been designed for discrete and continuous control in industrial environments such as manufacturing, food and beverages, and chemical industries worldwide.

VULNERABILITY CLASSIFICATION

The vulnerability classification has been performed by using the CVSS scoring system in version 3.0 (CVSS v3.0) (<https://www.first.org/cvss/>). The CVSS environmental score is specific to the customer's environment and will impact the overall CVSS score. The environmental score should therefore be individually defined by the customer to accomplish final scoring.

Vulnerability CVE-2018-16558

Specially crafted network packets sent to port 80/tcp or 443/tcp could allow an unauthenticated remote attacker to cause a Denial-of-Service condition of the device.

The security vulnerability could be exploited by an attacker with network access to the affected systems on port 80/tcp or 443/tcp. Successful exploitation requires no system privileges and no user interaction. An attacker could use the vulnerability to compromise availability of the device.

At the time of advisory publication no public exploitation of this security vulnerability was known.

CVSS v3.0 Base Score 7.5
CVSS Vector CVSS:3.0/AV:N/AC:L/PR:N/UI:N/S:U/C:N/I:N/A:H/E:P/RL:O/RC:C

Vulnerability CVE-2018-16559

Specially crafted network packets sent to port 80/tcp or 443/tcp could allow an unauthenticated remote attacker to cause a Denial-of-Service condition of the device.

The security vulnerability could be exploited by an attacker with network access to the affected systems on port 80/tcp or 443/tcp. Successful exploitation requires no system privileges and no user interaction. An attacker could use the vulnerability to compromise availability of the device.

At the time of advisory publication no public exploitation of this security vulnerability was known.

CVSS v3.0 Base Score 7.5
CVSS Vector CVSS:3.0/AV:N/AC:L/PR:N/UI:N/S:U/C:N/I:N/A:H/E:P/RL:O/RC:C

ACKNOWLEDGMENTS

Siemens thanks the following parties for their efforts:

- Georgy Zaytsev, Dmitry Sklyarov, Druzhinin Evgeny, Ilya Karpov, and Maxim Goryachy from Positive Technologies for coordinated disclosure

ADDITIONAL INFORMATION

For further inquiries on security vulnerabilities in Siemens products and solutions, please contact the Siemens ProductCERT:

<https://www.siemens.com/cert/advisories>

HISTORY DATA

V1.0 (2019-01-08): Publication Date

TERMS OF USE

Siemens Security Advisories are subject to the terms and conditions contained in Siemens' underlying license terms or other applicable agreements previously agreed to with Siemens (hereinafter "License Terms"). To the extent applicable to information, software or documentation made available in or through a Siemens Security Advisory, the Terms of Use of Siemens' Global Website (https://www.siemens.com/terms_of_use, hereinafter "Terms of Use"), in particular Sections 8-10 of the Terms of Use, shall apply additionally. In case of conflicts, the License Terms shall prevail over the Terms of Use.