SSA-325546: Denial-of-Service Vulnerabilities in EN100 Ethernet Communication Module of SWT3000

Publication Date: 2019-01-08
Last Update: 2019-01-08
Current Version: V1.0
CVSS v3.0 Base Score: 7.5

SUMMARY

The firmware variant IEC 61850 of the EN100 Ethernet communication module for SWT 3000 is affected by security vulnerabilities which could allow an attacker to conduct a Denial-of-Service attack over the network.

Siemens has released updates for several affected products, is working on updates for the remaining affected products, and recommends specific countermeasures until fixes are available.

AFFECTED PRODUCTS AND SOLUTION

Affected Product and Versions	Remediation
Firmware variant IEC 61850 for EN100 Ethernet module: All versions < V4.33	Update to V4.33. Applying the update causes the module to go through a single restart cycle. https://support.industry.siemens.com/cs/us/en/view/109745821

WORKAROUNDS AND MITIGATIONS

Siemens has identified the following specific workarounds and mitigations that customers can apply to reduce the risk:

• Block access to port 102/TCP e.g. with an external firewall.

GENERAL SECURITY RECOMMENDATIONS

Siemens strongly recommends applying the provided security updates using the corresponding tooling and documented procedures made available with the product. If supported by the product, an automated means to apply the security updates across multiple product instances may be used. Siemens strongly recommends prior validation of any security update before being applied, and supervision by trained staff of the update process in the target environment.

As a general security measure Siemens strongly recommends to protect network access with appropriate mechanisms (e.g. firewalls, segmentation, VPN). It is advised to configure the environment according to our operational guidelines in order to run the devices in a protected IT environment.

Recommended security guidelines to Secure Substations can be found at:

https://www.siemens.com/gridsecurity

PRODUCT DESCRIPTION

The EN100 Ethernet modules are used for enabling process communication using IEC 61850 protocols via electrical/optical 100 Mbit interfaces on SWT3000 devices.

VULNERABILITY CLASSIFICATION

The vulnerability classification has been performed by using the CVSS scoring system in version 3.0 (CVSS v3.0) (https://www.first.org/cvss/). The CVSS environmental score is specific to the customer's environment and will impact the overall CVSS score. The environmental score should therefore be individually defined by the customer to accomplish final scoring.

Vulnerability CVE-2018-11451

Specially crafted packets to port 102/tcp could cause a denial-of-service condition in the affected products. A manual restart is required to recover the EN100 module functionality of the affected devices.

Successful exploitation requires an attacker with network access to send multiple packets to the affected products or modules. As a precondition the IEC 61850-MMS communication needs to be activated on the affected products or modules. No user interaction or privileges are required to exploit the vulnerability. The vulnerability could allow causing a Denial-of-Service condition of the network functionality of the device, compromising the availability of the system.

At the time of advisory publication no public exploitation of this security vulnerability was known.

CVSS v3.0 Base Score 7.

CVSS Vector CVSS:3.0/AV:N/AC:L/PR:N/UI:N/S:U/C:N/I:N/A:H/E:P/RL:O/RC:C

Vulnerability CVE-2018-11452

Specially crafted packets to port 102/tcp could cause a denial-of-service condition in the EN100 communication module if oscillographs are running. A manual restart is required to recover the EN100 module functionality.

Successful exploitation requires an attacker with network access to send multiple packets to the EN100 module. As a precondition the IEC 61850-MMS communication needs to be activated on the affected EN100 modules. No user interaction or privileges are required to exploit the security vulnerability. The vulnerability could allow causing a Denial-of-Service condition of the network functionality of the device, compromising the availability of the system.

At the time of advisory publication no public exploitation of this security vulnerability was known.

CVSS v3.0 Base Score 5.9

CVSS Vector CVSS:3.0/AV:N/AC:H/PR:N/UI:N/S:U/C:N/I:N/A:H/E:P/RL:O/RC:C

ACKNOWLEDGMENTS

Siemens thanks the following parties for their efforts:

· Victor Nikitin, Vladislav Suchkov, and Ilya Karpov from ScadaX for coordinated disclosure

ADDITIONAL INFORMATION

For further inquiries on security vulnerabilities in Siemens products and solutions, please contact the Siemens ProductCERT:

https://www.siemens.com/cert/advisories

HISTORY DATA

V1.0 (2019-01-08): Publication Date

TERMS OF USE

Siemens Security Advisories are subject to the terms and conditions contained in Siemens' underlying license terms or other applicable agreements previously agreed to with Siemens (hereinafter "License Terms"). To the extent applicable to information, software or documentation made available in or through a Siemens Security Advisory, the Terms of Use of Siemens' Global Website (https://www.siemens.com/terms_of_use, hereinafter "Terms of Use"), in particular Sections 8-10 of the Terms of Use, shall apply additionally. In case of conflicts, the License Terms shall prevail over the Terms of Use.